

May 6, 2008

SKAW PRE-CAST  
JACK SKAW  
26255 105TH ST.  
NEW AUBURN WI 54757

Re: Description: SEWAGE TANKS, CONCRETE  
Manufacturer: SKAW PRE-CAST  
Product Name: SEPTIC, HOLDING, SIPHON, GREASE INTERCEPTOR OR PUMP  
Model Number(s): 1000 ROUND  
(52" L.L., 19.64 GAL/IN., 144" MAX. DEPTH OF BURY, 489 G.P.D. WHEN USED AS A  
SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL  
WASTEWATER)  
Product File No: 20080241

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of March 2011.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220 mg/L TSS, or greater than 30 mg/L or less than or equal to 150 mg/L TSS, and F.O.G. of less than 30 mg/L.
- This product is approved to use the following:
  - Four inch pipe inlet located in the edge of the tank cover.
  - Four inch discharge opening in riser.
  - Two inch schedule 40 PVC cast in riser for electrical wiring.
  - Four inch pipe openings located near the bottom of the side or end wall for siphon, pump and holding tanks.
  - Steel locking cover for the access opening.
  - Pipe materials constructed in conformance with Table 84.30-2 or 84.30-11, Wis. Admin. Code poured into tank cover or access cover.
  - Eight inch threaded plugged opening in access cover.
  - Six-inch diameter opening in lower portion of the interior wall for siphon, pump and holding tanks.
  - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
  - Press Seal "Cast-A-Seal" gasket by Press Seal Gasket Corp.

SKAW PRE-CAST

Page 2

May 6, 2008

20080241

This approval supersedes the approval issued on November 18 2005 under product file number 20050812.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20050812

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson  
Plumbing Product Reviewer  
Phone: 608-266-6742  
Fax: 608-267-9566  
E-mail: [Jerry.Thompson@wi.gov](mailto:Jerry.Thompson@wi.gov)